

NOTES:

1. INTERMEDIATE & BOTTOM RAILS SHALL BE CUT AND INSTALLED WITH 180° 2-WAY BRACE BANDS AND RAIL ENDS AT THE LINE POSTS; STANDARD BRACE BANDS AND RAIL ENDS AT THE TERMINAL POSTS.
2. ALL METAL MATERIALS SHALL BE BLACK VINYL COATED. ANY MATERIALS WITH DAMAGE TO THE VINYL COATING SHALL EITHER BE REMOVED & REPLACED OR RECOATED IN THE FIELD TO THE SATISFACTION OF THE CITY ENGINEER.
3. CHAIN LINK FABRIC SHALL BE 9 GAUGE CORE, 2" MESH WITH KNUCKLED FINISH TOP & BOTTOM EDGES. IT SHALL BE FASTENED TO END AND CORNER POSTS WITH $\frac{3}{16}$ " x $\frac{3}{4}$ " HIGH CARBON STEEL.
4. TENSION BAR SHALL HAVE 9 GAUGE CORE BANDS AT 16" INTERVAL.
5. FOOTING SHALL BE 5'-0" DEEP AND 18" IN DIAMETER WHEN THE CHAIN LINK IS 10'-0" IN HEIGHT, IS SLATTED OR HAS A WINDSCREEN APPLIED AND/OR IS RECOMMENDED BY GEOTECHNICAL CONDITIONS.



**ENGINEERING
DEPARTMENT**

CHAIN LINK FENCE NOTES

A handwritten signature in black ink, appearing to read "B. Grewal", written over a horizontal line.

BALWINDER S. GREWAL CITY ENGINEER

DATE: APR. 29, 2005

REVISED: JAN. 23, 2006

L-21b