



**MONOLITHIC SIDEWALK WITH BEVELED CURB (SECTION A-A)**

**NOTES:**

1. ALL CONCRETE SHALL BE CLASS B, 2500 P.S.I. MINIMUM; WITH 1 1/2 LBS. FIBRILLATED POLYPROPYLENE FIBERS PER CUBIC YARD.
2. BROOM FINISH WALK AT RIGHT ANGLES TO CURB; CURB AND GUTTER TO STREET.
3. ALL CONCRETE SHALL HAVE A MINIMUM 4" CUSHION OF CLASS 2 A.B. @ 95% RELATIVE COMPACTION (D1557-78) ON SUB-GRADE @ 95% RELATIVE COMPACTION. THE USE OF RECYCLED A.B. SHALL NOT BE ALLOWED.
4. ON EXPANSIVE NATIVE SOIL, 90% RELATIVE COMPACTION IS ACCEPTABLE ON SUBGRADE.
5. SEE ST-23 FOR TRANSITION LENGTH FROM BEVELED CURB TO STANDARD CURB. (Not To Scale)



**PUBLIC WORKS  
DEPARTMENT**



**RESIDENTIAL DRIVEWAY  
WITH MONOLITHIC SIDEWALK**

*B. Grewal*  
BALWINDER S. GREWAL CITY ENGINEER

DATE: AUG. 29, 2003  
REVISED: APRIL 25, 2007

SHEET NO.  
**ST-7a**