



SEPARATED SIDEWALK SECTION A-A

NOTES:

1. ALL CONCRETE SHALL BE CLASS B, 2500 P.S.I. MINIMUM; WITH 1 1/2 LBS. FIBRILLATED POLYPROPYLENE FIBERS PER CUBIC YARD.
 2. BROOM FINISH WALK AT RIGHT ANGLES TO CURB; CURB AND GUTTER TO STREET.
 3. ALL CONCRETE SHALL HAVE A MINIMUM 4" CUSHION OF CLASS 2 A.B. @ 95% RELATIVE COMPACTION (D1557-78) ON SUB-GRADE @ 95% RELATIVE COMPACTION. THE USE OF RECYCLED A.B. SHALL NOT BE ALLOWED.
 4. ON EXPANSIVE NATIVE SOIL, 90% RELATIVE COMPACTION IS ACCEPTABLE ON SUBGRADE.
- (Not To Scale)



**PUBLIC WORKS
DEPARTMENT**



**RESIDENTIAL DRIVEWAY
WITH SEPARATED SIDEWALK**

B. Grewal
BALWINDER S. GREWAL

CITY ENGINEER

DATE: AUG. 29, 2003
REVISED: APRIL 25, 2007

SHEET NO.
ST-7b