



NOTES:

1. RETAINING WALLS SHALL BE 2" x 12" PRE-TREATED WOOD. RETAINING WALLS HIGHER THAN 1' SHALL BE REINFORCED CONCRETE, CONCRETE BLOCKS OR MASONRY.
2. FOR RETAINING WALLS 3' OR HIGHER, USE G-3 OR G-4 OR G-5.
3. ALL RETAINING WALLS SHALL BE APPROVED BY THE CITY ENGINEER.
4. SEE G-2 FOR CUTS ADJACENT TO EXTERIOR PERIMETER PROPERTY LINES.

(Not To Scale)



**ENGINEERING
DEPARTMENT**

**EXTERIOR PERIMETER
PROPERTY LINE GRADING**

John E. Stevenson
JOHN E. STEVENSON
CITY ENGINEER

DATE: NOV. 30, 1998
REVISED: DEC. 29, 2000

SHEET NO.
G-1