



NOTES:

1. THE CONFIGURATION OF THE CAST IRON OR CAST STEEL FRAME AND COVER MAY VARY FROM THAT SHOWN.
2. FRAME SHALL BE EMBEDDED IN CONCRETE A MINIMUM OF 3".
3. ALL PORTLAND CEMENT CONCRETE SHALL BE CLASS "B" OR "MINOR" WITH 1" MAXIMUM AGGREGATE.
4. SURVEY MARKERS SHALL BE FURNISHED BY THE CONTRACTOR. INFORMATION TO APPEAR ON THE SURVEY MARKERS SHALL BE AS SHOWN ON SECTION A-A.
5. CALTRANS TYPE D MONUMENT ALT. NO. 1 OR ALT. NO. 2, WITH COVER MARKED "MONUMENT", MAY BE USED AT THE CONTRACTOR'S OPTION (NOTE 4 APPLIES).
6. STREET TIES SHALL BE SUBMITTED AFTER THE MONUMENT IS SET.
7. A LETTER MUST BE SENT TO THE CITY BY THE ENGINEER OF RECORD UPON SETTING THE MONUMENT.

(Not To Scale)



**ENGINEERING
DEPARTMENT**

BOXED SURVEY MONUMENT

John E. Stevenson
JOHN E. STEVENSON CITY ENGINEER

DATE: JAN. 31, 1999
REVISED: OCT. 31, 2000

SHEET NO.
ST-26