



NOTES:

1. RISER AT BUILDING SHALL BE TYPE L COPPER EXTENDING TO 12" BELOW FINISHED GRADE.
2. ALL RESIDENTIAL ANGLE METER STOP SHALL BE 1x1 WITH OPEN BORE.
3. SEE STANDARD PLAN W-6a FOR ADDITIONAL WATER SERVICE NOTES AND TYPICAL LAYOUT.

* OR APPROVED EQUAL
 ** FULL PORT BALL VALVE TYPE

MUELLER SERVICE SADDLE*	
6" MAIN	H-13441
8" MAIN	H-13442
10" MAIN	H-13443
12" MAIN	H-13444

(Not To Scale)



**ENGINEERING
 DEPARTMENT**

STANDARD WATER SERVICE

B.S. Grewal
 BALWINDER S. GREWAL
 CITY ENGINEER

DATE: JUNE 20, 2003
 REVISED: JAN. 20, 2005

SHEET NO.
W-5