

**APPROVED REDUCED PRESSURE
PRINCIPLE DEVICES**

MAKE*	MODEL*	SIZE
FEBCO	825-Y	3/4" - 2"
	825-YA	3/4" - 2"
	825-YD	2-1/2" - 10"
	850	2-1/2" - 10"
	860	2-1/2" - 10"
	870V	2-1/2" - 10"
	876 & 880	ALL
WATTS	909	3/4" - 2"
	773	ALL
	909	2-1/2" - 10"
	950	3/4" - 2"
WILKINS	475	4" - 8"
	950 & 975XL	3/4" - 2"
	975	2-1/2" - 10"
	350 SERIES	2-1/2" - 8"
	375 SERIES	2-1/2" - 8"

* OR EQUIVALENT AS APPROVED BY CITY ENGINEER

NOTE:

FOR THE BACKFLOW PREVENTION DEVICE STANDARD DETAILS, SEE W-8 AND W-9;
FOR THE FIRE PROTECTION ASSEMBLY, SEE W- 4.

**APPROVED DOUBLE CHECK DETECTOR
ASSEMBLIES FOR FIRE LINES**

(BYPASS METER MUST READ IN GALLONS)

MAKE*	MODEL*	SIZE
FEBCO	805-YD	ALL
	806-YD	ALL
	856	ALL
	876V	ALL
WATTS	709-DDC	ALL
WILKINS	450-DA	ALL
	950-DA	ALL
	350-DA	ALL

**APPROVED REDUCED PRESSURE
PRINCIPLE DETECTOR ASSEMBLIES**

(USED WHEN ANTIFREEZE IS USED IN
FIRE LINES; BYPASS METER MUST READ
IN GALLONS)

MAKE*	MODEL*	SIZE
FEBCO	826-YD	ALL
	860	ALL
	876V	ALL
WATTS	909	ALL
	993 RPDA	ALL
WILKINS	475-DA	ALL
	975-DA	ALL
	375-DA	ALL



**PUBLIC WORKS
DEPARTMENT**



**BACKFLOW PREVENTION DEVICE
ASSEMBLY LIST**

BALWINDER S. GREWAL CITY ENGINEER

DATE: JULY 21, 2003

REVISED: DEC. 3, 2007

SHEET NO.

W-8a