



NOTES:

1. ALL FITTINGS SHALL BE DUCTILE IRON.
2. FREEZE PROTECTION SHALL BE MADE OF WATER RESITANT CANVAS FILLED WITH R-19 FIBERGLASS INSULATION AND SHALL BE SIZED TO FIT THE DEVICE.
3. ALL BOLTS SHALL BE STAINLESS STEEL.
4. FOR A LIST OF APPROVED BACKFLOW PREVENTION DEVICE ASSEMBLY*, REFER TO STANDARD PLAN W-8a.
5. INSTALL CATHODIC PROTECTION ON ALL METALLIC RISERS PER CP-9.

(Not To Scale)



PUBLIC WORKS DEPARTMENT



**BACKFLOW PREVENTION DEVICE
3" TO 10" MAIN LINE**

BALWINDER S. GREWAL CITY ENGINEER

DATE: AUG. 15, 2003
REVISED: DEC. 3, 2007

SHEET NO.
W-9